

ATTESTATION OF CONFORMITY

Issued to: Wuxi Thinkpower New Energy Co., Ltd.
No. 6 Wenzhuang Road, Yixing Economic and Technological Development
Zone, Jiangsu, PRC

For the product: Three Phase Hybrid Inverter

Trade name: N/A

Type/Model: EPH4KTL, EPH5KTL, EPH6KTL, EPH8KTL, EPH10KTL, EPH12KTL

Ratings: EPH12KTL
PV max: 1000 Vdc, 200-850 Vdc, 13/13 A
Bat max: 25 A
Bat range: 180 ~ 650 Vdc
AC: 400 Vac, 50/60 Hz, 20 A, 13200 W, 13200 VA

Manufactured by: Wuxi Thinkpower New Energy Co., Ltd.
No. 6 Wenzhuang Road, Yixing Economic and Technological Development
Zone, Jiangsu, PRC

Requirements: EN IEC 61000-6-1:2019
EN IEC 61000-6-2:2019
EN IEC 61000-6-3:2021
EN IEC 61000-6-4:2019
EN 61000-3-12:2011
EN IEC 61000-3-11:2019

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no. 6133037.50

This Attestation implies that the examined types are in accordance with the standards designated under the Electromagnetic compatibility directive 2014/30/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Arnhem, 7 July 2022

Number: 6133037.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.

Kreny Lin
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

